

제 2019-46-15-00002 호(Certificate No. 2019-46-15-00002)

[1]종 압력용기 구조검사증

Class[1] Pressure Vessel Structural Inspection Certificate

성명(대표자) Name of representative	사업자등록번호 Corporate registration no.
상호 또는 명칭 Company Name	
사무소 소재지 Office address	(전화번호) (Phone No.)
사업소 소재지 Factory address	(전화번호) (Phone No.)

기 기 명 Equipment Name	살균기 (Sterilizer)	검사일자 Inspection Date	2019.02.11
용 량 Capacity	6.5 m ³	최고사용압력 MAWP	0.5/0.7 MPa

검사 사항 (Inspection items)	동체 shell		최대안지름(mm) Max inner diameter	1290	길이(mm) Length	4500	
	스태이 Stay	종 류 Type	재 료 Material	지름 또는 두께 Diameter or Thickness		동체, 경판 등에 부착방법 Method for attachment to Shell, Head, etc	
	뚜 꺽 판 체 결 볼 트 Cover Plate fastening bolt		재 료 Material	호칭지름(mm) Nominal diameter	개 수 EA		
			1.4307		1조		
	관 Tube	재 료 Material	바깥지름(mm) External diameter	개 수 EA		부 착 상 태 Attached State	
수 압 시 험 Hydrostatic Test		압 력 Pressure	0.97/1.43/0.97		상 태 Condition	pass	

「에너지이용 합리화법 시행규칙」 제31조의2제2항에 따라 발급합니다.

「Enforcement Decree of Energy Use Rationalization Act」 Issued in accordance with Paragraph 2 of Article 31-32

2019 . 05 . 07

기 관 장

President of Korea Energy Agency



첨부서류 Attachment	용접검사증(용접검사가 면제된 경우에는 그 설계도면) 1부(구조검사를 신청할 때 해당 검사대상기기의 용접검사증 또는 설계도면을 첨부한 경우만 해당합니다.) Welding Inspection Certificate(For drawing review exemption - Design Drawing of the equipment subject to inspection), 1copy (Applicable only when the Welding Inspection Certificate or Design Drawing of the equipment subject to inspection is attached when applying for Structural Inspection)
--------------------	---